

Subject Pump proposals and invoice

From Patrick Sullivan <patrick@livingstoncre.com>
To Vrtx <claude@vrtxinc.com>
Cc Steve Trebatch <steve@livingny.com>
Date 2019-05-30 15:12



- 534 West 42nd Boiler #2 Pump repair proposal.pdf(~446 KB)
- 534 W42nd New Proposal for fire pump.pdf(~467 KB)
- 534 Service call invoice for fire pump 5-29-19.pdf(~222 KB)

Claude & Steve,

GM Pump went to the building yesterday and partially took the fire pump apart and discovered the internal sleeve was broken. They said the pump would have to be removed and brought back to the shop. Attached is the new proposal and the invoice for yesterday's work. They said the fire pump can be removed on Monday and returned on Tuesday.

The proposal for the boiler circulating pump is also attached. GM Pump will need to remove the pump and bring it back to the shop to rebuild it. They can remove this pump on Monday as well and bring it back on Tuesday.

Let me know if you would like to proceed.

Regards,

Patrick Sullivan
Property Manager
646-214-0366 Direct Line
212-810-4162 Fax
patrick@livingstoncre.com
Livingston Management Services LLC
225 West 35th Street, 14th Floor
New York, NY 10001-1904