

PREMISES 534 West 42nd Street, NY, NY 10036

SPRINKLER EQUIPMENT IN THIS BUILDING IS INSPECTED MONTHLY

2021
9/10/2018

CERTIFICATE OF FITNESS HOLDER Patrick Sullivan CERTIFICATE # 86518834 EXP. DATE 7/15/2018

5-12 86518834

5-13 86605193

11/09/2018

YEAR 2018

2021

MONTH	VALVES LOCKED	EXTRA SPK HEADS	ARE SIGNS IN PLACE	CONDITION OF SPRINKLER PIPING	CONDITION OF SPRINKLER HEADS	SIAMESE CONNECTION	ALARM DEVICE	WATER PRESSURE	INITIALS & NOTES
JAN	Plow switch openbox	Need to Sprinkler control	SPRinkler control	good	good	MISSING cap	ok	82	Non painted FONYK, L missing signs cover
FEB	✓	✓	✓	ok	ok	4	ok	82	✓
MAR	✓	✓	✓	OK	ok	on order	ok	82	✓
APR	✓	✓	✓	ok	ok	"	ok	82	✓
MAY	✓	✓	✓	ok	ok	"	ok	82	✓
JUN	✓	✓	✓	ok	ok	"	ok	82	✓
JUL	✓	✓	✓	ok	ok	✓	ok	82	✓
AUG	✓	✓	✓	ok	ok	✓	ok	82	✓
SEPT	✓	✓	✓	ok	ok	✓	ok	81	✓
OCT	✓	✓	✓	ok	ok	good	ok	82	✓
NOV	✓	✓	✓	ok	ok	good	ok	82	✓
DEC	✓	✓	✓	ok	ok	good	ok	82	✓

• Assure siamese connection(s) are not blocked and caps are in place and painted appropriately.

• If valves are locked note "yes" if they are not locked, relock and note "locked."

• Inspect alarm valve to assure no leakage from retard chamber or alarm drain.

• Assure there is proper number and type of extra sprinkler heads and wrench.