

Empire Fire Sprinkler LLC
222 East 18th Street New
York, NY 10003
212-433-0720

PREMISES 534 W 42nd St, New York, NY 10036



SPRINKLER EQUIPMENT IN THIS BUILDING IS INSPECTED MONTHLY

CERTIFICATE OF FITNESS HOLDER Patrick Sullivan

CERTIFICATE # 86518834

EXP. DATE 09/10/2024

YEAR 2024

MONTH	VALVES LOCKED	EXTRA SPK HEADS	ARE SIGNS IN PLACE	CONDITION OF SPRINKLER PIPING	CONDITION OF SPRINKLER HEADS	SIAMESE CONNECTION	ALARM DEVICE	WATER PRESSURE	INITIALS & NOTES
JAN 26	✓	✓	✓	04	04	04	04	161	
FEB 29	✓	✓	✓	04	04	04	04	135	
MAR 29	✓	✓	✓	04	04	04	04	160	
APR 26	✓	✓	✓	04	04	04	04	155	
MAY 10	✓	✓	✓	04	04	04	04	130	
JUN 5	✓	✓	✓	04	04	04	04	150	
JUL 16	✓	✓	✓	04	04	04	04	154	
AUG 29	✓	✓	✓	04	04	04	04	142	
SEPT 10	✓	✓	✓	04	04	04	04	164	
OCT 24	✓	✓	✓	04	04	04	04	201	
NOV									
DEC									

• Assure siamese connection(s) are not blocked and caps are in place and painted appropriately.

• If valves are locked note "yes" if they are not locked, relock and note "locked."

• Inspect alarm valve to assure no leakage from retard chamber or alarm drain.

• Assure there is proper number and type of extra sprinkler heads and wrench.