

## **Claude Simon**

---

**From:** claudie@charleshenryproperties.com  
**Sent:** Monday, December 16, 2013 9:44 PM  
**To:** mpadua08@yahoo.com  
**Subject:** Fire Hall Blockage

Mike-

There is no way around it.

The fire hall must be free of obstructions.

According to NYC Fire Code:

1027.3 Unobstructed and unimpeded egress required.

All required means of egress, including each exit, exit access and exit discharge, shall be continuously maintained free from obstructions and impediments to immediate use in the event of fire or other emergency.

Please remove all your personal property from the fire hall as soon as possible.

This represents not only a violation but a serious, life-threatening safety hazard.

Sincerely,

Claude Simon