

PREMISES

534 W 42nd Street, NY, NY 10036

SPRINKLER EQUIPMENT IN THIS BUILDING IS INSPECTED MONTHLY

CERTIFICATE OF FITNESS HOLDER

Patrick Sullivan

CERTIFICATE # 86518834

S-12

EXP. DATE 9/10/2021

YEAR 2019

S13 86605193

11/09/2021

MONTH	VALVES LOCKED	EXTRA SPK HEADS	ARE SIGNS IN PLACE	CONDITION OF SPRINKLER PIPING	CONDITION OF SPRINKLER HEADS	SIAMESE CONNECTION	ALARM DEVICE	WATER PRESSURE	INITIALS & NOTES
JAN	✓	✓	✓	good	good	good	good	86	PS
FEB	✓	✓	✓	good	good	good	good	70	B
MAR	✓	✓	✓	good	good	good	good	90	B
APR	✓	✓	✓	good	good	good	good	90	P
MAY	✓	✓	✓	good	good	good	good	90	F
JUN	✓	✓	✓	good	good	good	good	90	HC
JUL	✓	✓	✓	good	good	good	good	90	HC
AUG	✓	✓	✓	good	good	good	good	90	
SEPT	✓	✓	✓	good	good	good	good	90	
OCT	✓	✓	✓	good	good	good	good	90	PS
NOV	✓	✓	✓	good	good	good	good	90	✓
DEC	✓	✓	✓	good	good	good	good	90	✓

Assure siamese connection(s) are not blocked and caps are in place and painted appropriately.

If valves are locked note "yes" if they are not locked, relock and note "locked."

Inspect alarm valve to assure no leakage from retard chamber or alarm drain.

Assure there is proper number and type of extra sprinkler heads and wrench.