

Empire Fire Sprinkler LLC
222 E 18th Street
New York, NY 10003 PREMISES
212-725-1708
www.EmpireSprinkler.com

534 W 42nd St New York, NY 10036

SPRINKLER EQUIPMENT IN THIS BUILDING IS INSPECTED MONTHLY

CERTIFICATE OF FITNESS HOLDER Patrick Sullivan CERTIFICATE # 86518834 EXP. DATE 9/10/2024

YEAR 2021

MONTH	VALVES LOCKED	EXTRA SPK HEADS	ARE SIGNS IN PLACE	CONDITION OF SPRINKLER PIPING	CONDITION OF SPRINKLER HEADS	SIAMESE CONNECTION	ALARM DEVICE	WATER PRESSURE	INITIALS & NOTES
JAN	✓	✓	✓	OK	OK	OK	OK	150	ES
FEB	✓	✓	✓	OK	OK	OK	OK	127	ES
MAR	✓	✓	✓	OK	OK	OK	OK	142	ES
APR	✓	✓	✓	OK	OK	OK	OK	139	ES
MAY	✓	✓	✓	OK	OK	OK	OK	150	ES
JUN	✓	✓	✓	OK	OK	OK	OK	139	ES
JUL	✓	✓	✓	OK	OK	OK	OK	122	ES
AUG	✓	✓	✓	OK	OK	OK	OK	137	ES
SEPT	✓	✓	✓	OK	OK	OK	OK	137	ES
OCT	✓	✓	✓	OK	OK	OK	OK	129 (130)	ES
NOV	✓	✓	✓	OK	OK	OK	OK	134	ES
DEC	✓	✓	✓	OK	OK	OK	OK	144	ES

- Assure siamese connection(s) are not blocked and caps are in place and painted appropriately.
- If valves are locked note "yes" if they are not locked, relock and note "locked."
- Inspect alarm valve to assure no leakage from retard chamber or alarm drain.
- Assure there is proper number and type of extra sprinkler heads and wrench.