

Empire Fire Sprinkler LLC  
222 East 18th Street New  
York, NY 10003  
212-725-1708

PREMISES 534 W 42nd Street, New York, NY 10036

SPRINKLER EQUIPMENT IN THIS BUILDING IS INSPECTED MONTHLY

CERTIFICATE OF FITNESS HOLDER Patrick Sullivan

CERTIFICATE # 86518834

EXP. DATE 09/10/2024

YEAR 2022

| MONTH | VALVES LOCKED | EXTRA SPK HEADS | ARE SIGNS IN PLACE | CONDITION OF SPRINKLER PIPING | CONDITION OF SPRINKLER HEADS | SIAMESE CONNECTION <u>PDC</u> | ALARM DEVICE | WATER PRESSURE | INITIALS & NOTES |
|-------|---------------|-----------------|--------------------|-------------------------------|------------------------------|-------------------------------|--------------|----------------|------------------|
| JAN   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 127            |                  |
| FEB   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 134            |                  |
| MAR   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 143            |                  |
| APR   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 135            |                  |
| MAY   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 134            |                  |
| JUN   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 135            |                  |
| JUL   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 135            |                  |
| AUG   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 139            |                  |
| SEPT  | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 135            |                  |
| OCT   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 138            |                  |
| NOV   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 139            |                  |
| DEC   | ✓             | ✓               | ✓                  | OK                            | OK                           | OK                            | OK           | 140            |                  |

• Assure siamese connection(s) are not blocked and caps are in place and painted appropriately.

• If valves are locked note "yes" if they are not locked, relock and note "locked."

• Inspect alarm valve to assure no leakage from retard chamber or alarm drain.

• Assure there is proper number and type of extra sprinkler heads and wrench.