

Empire Fire Sprinkler LLC
222 East 18th Street New
York, NY 10003
212-725-1708

PREMISES

534 W 42nd Street, New York, NY 10036

SPRINKLER EQUIPMENT IN THIS BUILDING IS INSPECTED MONTHLY

CERTIFICATE OF FITNESS HOLDER Patrick Sullivan

CERTIFICATE # 86518834

EXP. DATE 09/10/2024

YEAR 2023

MONTH	VALVES LOCKED	EXTRA SPK HEADS	ARE SIGNS IN PLACE	CONDITION OF SPRINKLER PIPING	CONDITION OF SPRINKLER HEADS	SIAMESE CONNECTION	ALARM DEVICE	WATER PRESSURE	INITIALS & NOTES
JAN	✓	✓	✓	OK	OK	OK	OK	137	
FEB	✓	✓	✓	OK	OK	OK	OK	140	
MAR	✓	✓	✓	OK	OK	OK	OK	151	
APR	✓	✓	✓	OK	OK	OK	OK	136	Notes FDC corrected
MAY	✓	✓	✓	OK	OK	OK	OK	145	
JUN	✓	✓	✓	OK	OK	OK	OK	137	
JUL	✓	✓	✓	OK	OK	OK	OK	139	
AUG	✓	✓	✓	OK	OK	OK	OK	149	
SEPT	✓	✓	✓	OK	OK	OK	OK	149	
OCT	✓	✓	✓	OK	OK	OK	OK	129	
NOV	✓	✓	✓	OK	OK	OK	OK	145	
DEC	✓	✓	✓	OK	OK	OK	OK	155	

- Assure siamese connection(s) are not blocked and caps are in place and painted appropriately.
- If valves are locked note "yes" if they are not locked, relock and note "locked."
- Inspect alarm valve to assure no leakage from retard chamber or alarm drain.
- Assure there is proper number and type of extra sprinkler heads and wrench.