CLEARSPAN FRAME COLUMN
OR ENDWALL COLUMN PER
PLAN AND MEMBER SCHEDULE

CONCRETE SLAB PER DETAIL
Y/2 ON ORIGINAL DRAWINGS

POUR JOINT

8"

"H"

"TSB"

8"

UNDISTURBED NATIVE SOIL (ANY
OVER-EXCAVATION MUST BE
BACKFILLED EITHER WITH 2000 PSI
CONCRETE OR WITH CLEAN SAND
THOROUGHLY COMPACTED BY
TAMPING IN LAYERS NOT MORE
THAN 8" IN DEPTH)

#__ VERTICAL BARS WITH 90°
6" LONG HOOK INTO SLAB,
SPACED @ __" O.C.

#__ CONT. HORIZONTAL BARS
AT __" O.C.

"FD" MIN.

"TF"

3" CLR.

"FB"

POUR JOINT

| Z | RAISED SLAB ALTERNATE FDN. DETAIL | SCALE: NO SCALE |