



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Cellar

Tag Name: main feed #2

Tag #: EQ00404228

Location: water meter room

Valve Tag Color: green

Model Number: 4inch

Manufacturer: OS&Y

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Cellar

Tag Name: main feed 3

Tag #: EQ00413039

Valve Tag Color: green

Model Number: 4inch

Manufacturer: OS&Y

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Basement

Tag Name: Fire pump bypass

Tag #: EQ00416966

Location: Fire Pump Room

Valve Tag Color: green

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Basement

Tag Name: Jockey discharge

Tag #: EQ00413541

Location: Fire Pump Room

Valve Tag Color: green

Manufacturer: Nibco

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Basement

Tag Name: Jockey suction

Tag #: EQ00405653

Location: Fire Pump Room

Valve Tag Color: green

Manufacturer: Nibco

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer Floor: Basement Tag Name: Fire pump feed Control valve

Tag #: EQ00411318 Location: Fire Pump Room

Valve Tag Color: green

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Basement

Tag Name: Main feed 1

Tag #: EQ00407526

Location: Water Meter Room

Valve Tag Color: green

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Basement

Tag Name: Fire pump suction

Tag #: EQ00413423

Location: Fire Pump Room

Valve Tag Color: green

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	Yes

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Control Valves

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Basement

Tag Name: Fire pump discharge

Tag #: EQ00404299

Location: Fire Pump Room

Valve Tag Color: green

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annually Inspection for Control Valves

• Control valves in normal open or closed position	Yes
• Control valves properly locked or supervised	Yes
• Control valves accessible	Yes
• Control valves provided with appropriate wrenches	N/A
• Control valves free from external leaks	Yes
• Control valve identification signs in place/does sign indicate area served	Yes
• Comments	Yes

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Basement

Tag Name: Wet sprinkler basement

Tag #: EQ00405732

Valve Tag Color: green

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	N/A	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	N/A
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	Yes
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	75
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	50
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Lobby

Tag Name: Wet sprinkler system 1a

Tag #: EQ00413318

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	N/A	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	Yes
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	100
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	70
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Floor 2

Tag Name: Wet sprinkler system 2b

Tag #: EQ00404257

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	N/A	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	Yes
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	100
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	75
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Floor 3

Tag Name: Wet sprinkler system 3a

Tag #: EQ00408992

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	N/A	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	Yes
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	100
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	75
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Floor 4

Tag Name: Wet sprinkler system 4b

Tag #: EQ00398380

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	N/A	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	N/A
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	100
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	75
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Floor 5

Tag Name: Wet sprinkler system 5a

Tag #: EQ00404271

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	Yes	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	N/A
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	100
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	75
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Floor 6

Tag Name: Wet sprinkler system 6b

Tag #: EQ00408969

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	N/A
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	N/A	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	N/A
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	90
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	50
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Floor 7

Tag Name: Wet sprinkler system 7a

Tag #: EQ00405579

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	Yes	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	N/A
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	75
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	40
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Floor 8

Tag Name: Wet sprinkler system 8

Tag #: EQ00405486

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	N/A	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	Yes
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	75
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	50
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes	System returned to service	<input checked="" type="checkbox"/>
		Tamper Activated	<input checked="" type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026



MAINTENANCE CORPORATION

1750 Plaza Ave, +1 516-593-2000

Report of Inspection, Testing & Maintenance of Wet Pipe Sprinkler Systems

Inspection Frequency: annually

WO#: 271811

Date: 01/07/2026

Inspected Property: 534 WEST 42ND STREET CONDOMINIUM, 534 West 42nd Street, New York, NY 10036, US

Tradesmen Name: Shawn Palmer

Floor: Floor 9

Tag Name: Wet sprinkler system 9

Tag #: EQ00412343

Valve Tag Color: yellow

Manufacturer: Victalic

Custom ID: S12 COF#91536391 EXP 02/23/2028, S13 COF#91536441 EXP 02/23/2028

Custom ID: S13 COF#92050699 EXP 05/15/2026

Annual Testing for Wet Pipe Sprinkler Systems		Annual Inspection for Wet Pipe Sprinkler Systems	
• System in service before testing	Yes	• System in service on inspection	Yes
• Pertinent parties notified before testing	Yes	• Hangers and seismic bracing appears undamaged and tightly attached	Yes
• Adequate drainage provided before flow testing	N/A	• Piping appears free of mechanical damage	Yes
• Main drain test conducted	Yes	• Piping appears free of leakage	Yes
• Full flow pressure (residual) < 10 percent reduction from prior or original test	N/A	• Piping appears free of corrosion	Yes
• Antifreeze system has a test connection at the most remote portion, the interface with the wet pipe system, and when the capacity exceeds 150 gal. one additional connection for every 100 gal	N/A	• Piping appears free of external loading	Yes
• Control valves (including backflow and PIVs) operated through full range and returned to normal position	Yes	• Sprinklers appear free of leakage	Yes
• PIVs opened until spring or torsion felt in rod	N/A	• Sprinklers appear free of corrosion	Yes
• PIVs and OS&Ys backed 1/4 turn from full open	N/A	• Sprinklers appear free of foreign materials	Yes
• Main drain test conducted (see F.2.0)	Yes	• Sprinklers appear free of paint	Yes
• Backflow prevention assembly forward flow test conducted	N/A	• Sprinklers appear free of physical damage	Yes
• System demand flow was achieved through the device	Yes	• Sprinklers appear properly oriented	Yes
• Forward flow test conducted without measuring flow (device < 2" and outlet sized to flow system demand)	N/A	• Clearance appears to be adequate between sprinkler and building contents	Yes
• Backflow prevention assembly internal inspection conducted (where shortages last more than 1 year and rationing enforced by AHJ)	N/A	• Glass bulbs appear full of liquid	N/A
• Forward flow test satisfied by annual fire pump flow test	N/A	• Spare sprinklers are of proper number (at least 6), type and temperature rating	N/A
• Backflow preventer flow test conducted as required by the AHJ	N/A	• Spare sprinklers stored where temperature maximum is 100°F	N/A
• PRV control valves partial flow test conducted and adequate to unseat valve	N/A	• Wrench available for each type of sprinkler	N/A
• Pertinent parties notified of test conclusion	Yes	• Prior to freezing weather	Yes
		• Building is secure such as not to expose piping to freezing conditions	Yes
		• Adequate heat is provided maintaining temperatures at 40°F or higher	Yes

Annual Maintenance for Wet Pipe Sprinkler Systems		Results	
• System in service before conducting maintenance	Yes	Supply water gauge reading before flow (static)	75
• Pertinent parties notified before conducting maintenance	Yes	Gauge reading during stable flow (residual)	50
• Operating stems of OS&Y (including backflow) valves lubricated	N/A	Antifreeze solution freezing point	
• Valve completely closed and reopened	Yes	Antifreeze solution freezing point after adjustment	
• Adequate drainage provided before flow testing	N/A	Comments	
• Main drain test conducted	Yes	TEST RESULTS:	
• Pertinent parties notified after conclusion of maintenance	Yes		

System returned to service		<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tamper Activated		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(All "NO" answers to be explained.) OWNER/DESIGNATED REP.

Inspector Initial: S P

INITIAL: _____

Date: 01/07/2026